

Contra Costa County



CONTRA COSTA Fire Protection District

08 JUL -7 PM 2:17

DEPARTMENT OF CONSERVATION
AND DEVELOPMENT

Fire Chief
KEITH RICHTER

July 2, 2008

Ms. Deidra Dingman
Contra Costa County
Community Development Department
651 Pine Street, 4th Floor
Martinez, CA 94553

Subject: LP08-2026; Keller Canyon Landfill Company
901 Bailey Road, Pittsburg
CCCFPD Project No.: 109856-PL

Dear Ms. Dingman:

We have reviewed the land use permit application to increase tonnage input to the landfill facility at the subject location. **If this project is approved by your office, the following shall be included as part of the conditions of approval in accordance with the Health and Safety Code and the 2007 California Fire Code (CFC):**

1. Approved material handling equipment shall be available for moving wood chips, hogged material, wood fines and raw product during firefighting operations. (1908.9) CFC
2. Portable fire extinguishers with a minimum rating of 2-A:60-B:C shall be provided on all vehicles and equipment operating on piles, and at all processing equipment. (1908.8) CFC
3. Piles shall be separated from adjacent piles by a minimum separation of 20 feet, providing access for fire apparatus. Piles shall not exceed 25 feet in height, 150 feet in width and 250 feet in length. (1908.3) CFC
4. Approved means shall be provided to monitor and measure temperatures within any static piles. Internal pile temperatures shall be monitored and recorded weekly. All records shall be kept on file at the facility and be made available for inspection. (1908.6) CFC

The above-referenced CCCFPD Project Number shall be required in all correspondence or communication with the Fire District.

Our preliminary review comments shall not be construed to encompass the complete project. Additional plans and specifications may be required after further review.

Please provide this office with a copy of the conditions of approval as set forth by your Planning Division for our files.

If you have any questions regarding this matter, please contact this office at 925.941.3300.

Sincerely,



Ted Leach
Fire Prevention Technician

TL/mm

c: Kevin Chiapello
901 Bailey Road
Pittsburg, CA 94565